

PRINCIPALS

Daniel W. Mitchell
Nancy M. D. Faught
Keith D. McCormack
Jesse B. VanDeCreek
Roland N. Alix
Michael C. MacDonald
James F. Burton
Charles E. Hart

CONTROLLER

Donna M. Martin

SENIOR ASSOCIATES

Gary J. Tressel
Randal L. Ford
William R. Davis
Dennis J. Benoit
Robert F. DeFrain
Thomas D. LaCross
Albert P. Mickalich
Timothy H. Sullivan
Thomas G. Maxwell

ASSOCIATES

Marshall J. Grazioli
Colleen L. Hill-Stramsak
Bradley W. Shepler
Karyn M. Stickel
Jane M. Graham
Todd J. Sneathen
Aaron A. Uranga
Salvatore Conigliaro
Melissa A. Coatta
Michael P. Darga
Brian K. Davies
James E. Scholl
Matthew G. Slicker
James J. Surhigh
Trevor S. Wagenmaker

HUBBELL, ROTH & CLARK, INC.

STREET: 2101 Aurelius Road, Suite 2A
Holt, MI 48842

PHONE: 517-694-7760

WEBSITE: hrcengr.com

OTHER OFFICE LOCATIONS

Bloomfield Hills
Detroit
Grand Rapids
Howell
Jackson
Kalamazoo
Lansing

ADDENDUM NO. 1
2018 EATON RAPIDS SEWER CLEANING AND TELEVISIONING
CITY OF EATON RAPIDS
EATON COUNTY, MICHIGAN

June 8, 2018

HRC Job No. 20140285

ONLINE ONLY

<http://www.hrcengr.com/bid-info/>

INTENT:

This Addendum No. 1 is issued prior to receipt of bids to provide for certain changes and clarifications to the specifications and/or the plans, as herein specified, and is hereby made a part of the Contract Documents and shall be taken into consideration in preparing the Proposal. The General Conditions and Specifications for the original work and the Contract Drawings are to govern this work unless otherwise revised herein. All other conditions remain the same.

The Bidder shall acknowledge the receipt of this Addendum on Page 00300/6 of Proposal.

CONTRACTOR QUESTIONS

- Q: In the specifications for this project it says that normal cleaning should be included in the line items for Internal Video Inspection with PACP. Should we include cleaning in these line items?
A: Normal cleaning of a line should be included in the line items for internal video inspection of that line.
- Q: Can fire hydrants be used to fill cleaning equipment? Are there any special requirements to do this?
A: The City will provide one meter with backflow preventer on one hydrant during the duration of the work. Water will be billed at a rate of \$3.47 per 1,000 gallons of water.
- Q: Can debris from the cleaning operations be disposed at the wastewater plant?
A: Debris may be disposed at the wastewater treatment plant at no charge.

A copy of the amended pages of the Contract Documents noted in this Addendum No. 1 have been posted online at <http://www.hrcengr.com/bid-info/> and should be utilized during the preparation of the bids and incorporated into the Bid Documents.

The Contractor shall acknowledge receipt of this Addendum No. 1 by signing in the location provided below and incorporating this Addendum No. 1 with the submission of this bid.

Failure to include Addendum No. 1 and its attachments may result in rejection of the bid.

If you have any questions or require any additional information, please contact the undersigned.

Very truly yours,

HUBBELL, ROTH & CLARK, INC.



Michael A. Romkema, P.E.

MAR/sab

pc: All Prospective Bidders
City of Eaton Rapids; A. Desentz
HRC; T. Sneathen, N. Womack, S. Carver, File

Accepted by:

Company Name: _____

Name: _____

Written Name: _____

Address: _____

Telephone: _____ Fax: _____