

PRINCIPALS

Daniel W. Mitchell
Nancy M.D. Faught
Keith D. McCormack
Jesse B. VanDeCreek
Roland N. Alix
Michael C. MacDonald
James F. Burton
Charles E. Hart
Todd J. Sneathen

CONTROLLER

Donna M. Martin

SENIOR ASSOCIATES

Gary J. Tressel
Randal L. Ford
William R. Davis
Dennis J. Benoit
Robert F. DeFrain
Thomas D. LaCross
Albert P. Mickalich
Timothy H. Sullivan
Thomas G. Maxwell

ASSOCIATES

Marshall J. Grazioli
Colleen L. Hill-Stramsak
Bradley W. Shepler
Karyn M. Stickel
Jane M. Graham
Aaron A. Uranga
Salvatore Conigliaro
Melissa A. Coatta
Michael P. Darga
Brian K. Davies
Matthew G. Slicker
James J. Surhigh
Trevor S. Wagenmaker

HUBBELL, ROTH & CLARK, INC.

STREET: 535 Griswold Street
Buhl Building, Suite 1650
Detroit, MI 48226-3698

PHONE: 313-965-3330

WEBSITE: hrcengr.com

OTHER OFFICE LOCATIONS

Bloomfield Hills
Delhi Township
Grand Rapids
Howell
Jackson
Kalamazoo
Lansing

**ADDENDUM NO. 3
FOR THE
COLLECTIONS SYSTEM IMPROVEMENTS
DELHI CHARTER TOWNSHIP
HOLT, MICHIGAN**

ISSUED: November 23, 2018

HRC Job No. 20180132

This Addendum No. 3 is issued prior to receipt of bids to provide for certain changes and clarifications to the specifications and/or the Drawings, as herein specified, and is hereby made a part of the Contract Documents and shall be taken into consideration in preparing the Proposal. All other conditions remain the same. **The Proposer shall acknowledge the receipt of this Addendum by signing below, including this addendum with their proposals, and completing the Addenda section on Page 5 of the Proposal Form (Section 00150).** Failure to sign the Addenda Section of the Proposal Form in the submission of the proposal may be justification for the proposal being rejected as non-responsive.

The following lists the extent of this Addendum.

CONTRACTOR QUESTIONS

Q1: When is the cut-off date for questions for the project?

A1: Tuesday, November 27, 5:00PM EST

Q2: Do you have a sign in sheet or list of contractors that attended the prebid meeting for the Collections System Improvements – Delhi Charter Township project?

A2: The pre-bid meeting was cancelled via Addendum 1. A Plan Holders List is available under Bid Info on the HRC website, hrcengr.com.

Q3: What is the square footage and product materials for this job?

A3: Michael Street will be replacement of 130 LF of 8" sanitary sewer, PVC SDR 26.
Delhi Commerce will be installation of 1436 LF of 10" sanitary sewer, PVC SDR 26.

A copy of the amended pages of the Contract Documents noted in this Addendum No. 3 have been posted online at <http://www.hrcengr.com/bid-info/> and should be utilized during the preparation of the bids and incorporated into the Bid Documents.

If you have any questions or require any additional information, please contact the undersigned.

Very truly yours,

HUBBELL, ROTH & CLARK, INC.



Prasad Gullapalli, P.E.

pc: All Prospective Bidders
Delhi Charter Township; S. Diorka
HRC; T. Sneathen, N. Womack, S. Carver, File

Received and Acknowledged by:

Company Name: _____

Name: _____

Written Name: _____

Address: _____

Telephone: _____ Fax: _____