

PRINCIPALS

Daniel W. Mitchell
Nancy M.D. Faught
Keith D. McCormack
Jesse B. VanDeCreek
Roland N. Alix
Michael C. MacDonald
James F. Burton
Charles E. Hart
Todd J. Sneathen

CONTROLLER

Donna M. Martin

SENIOR ASSOCIATES

Gary J. Tressel
Randal L. Ford
William R. Davis
Dennis J. Benoit
Robert F. DeFrain
Thomas D. LaCross
Albert P. Mickalich
Timothy H. Sullivan
Thomas G. Maxwell

ASSOCIATES

Marshall J. Grazioli
Colleen L. Hill-Stramsak
Bradley W. Shepler
Karyn M. Stickel
Jane M. Graham
Aaron A. Uranga
Salvatore Conigliaro
Melissa A. Coatta
Michael P. Darga
Brian K. Davies
Matthew G. Slicker
James J. Surhigh
Trevor S. Wagenmaker

HUBBELL, ROTH & CLARK, INC.

STREET: 535 Griswold Street
Buhl Building, Suite 1650
Detroit, MI 48226-3698
PHONE: 313-965-3330
WEBSITE: hrcengr.com

OTHER OFFICE LOCATIONS

Bloomfield Hills
Delhi Township
Grand Rapids
Howell
Jackson
Kalamazoo
Lansing

**ADDENDUM NO. 4
FOR THE
COLLECTIONS SYSTEM IMPROVEMENTS
DELHI CHARTER TOWNSHIP
HOLT, MICHIGAN**

ISSUED: November 28, 2018

HRC Job No. 20180132

This Addendum No. 4 is issued prior to receipt of bids to provide for certain changes and clarifications to the specifications and/or the Drawings, as herein specified, and is hereby made a part of the Contract Documents and shall be taken into consideration in preparing the Proposal. All other conditions remain the same. **The Proposer shall acknowledge the receipt of this Addendum by signing below, including this addendum with their proposals, and completing the Addenda section on Page 5 of the Proposal Form (Section 00150).** Failure to sign the Addenda Section of the Proposal Form in the submission of the proposal may be justification for the proposal being rejected as non-responsive.

The following lists the extent of this Addendum.

CONTRACTOR QUESTIONS

- Q1: I assume that the Rim Elevation listed for Sanitary Manhole 07 should be 879.31 as opposed to 889.31?
- A1: Yes, the Rim Elevation listed for Sanitary Manhole 07 should 879.31.
- Q2: Will the bid date be extended to accommodate any of the questions you received?
- A2: No the bid date will not be extended.
- Q3: In addendum #2 boring for Michael Avenue are provided, can boring be provided for the rest of the project, ie. the work along Willoughby and Delhi-Commerce road?
- A3: Additional boring information for Willoughby and Delhi Commerce Roads will not be provided at this time.
- Q4: On sheet 03 under pavement replacement, aggregate base 21AA modified OR a 4G is called for, depending on which page you look at. Which material do you require and if it is a modified or a special what is the specification for the material?
- A4: Use aggregate base 21AA.
- Q5: Will the owner be coordinating the decommissioning of the utilities for the transformer and pump station?
- A5: The Engineer will coordinate.

- Q6: For the Delhi/Commerce portion of the work, what item are the cleanouts to be paid under?
- A6: See Specification 01001 Special Project Notes.
- Q7: Are there plans that show the existing layout of the pump station, diameter of wetwell, etc?
- A7: See the Plans and Specifications provided. Additional plans will not be provided at this time.
- Q8: Are any of the interior items to be salvaged for the owner?
- A8: No.
- Q9: The existing sewer needs to be removed as the proposed sewer is installed, the sanitary sewer leads need to be connected to the new sewer as it is installed. Air testing cannot be completed with sanitary leads connected. Can additional televising of the proposed main be substituted for pressure testing?
- A9: Pressure testing will not be required for existing leads. Other testing mentioned in the specifications will be required.
- Q10: On the Michael portion of the project, plan shows a 2' of aggregate stone base. Is this paid for as trench undercut for the excavation, and then geogrid 1x3 for the material?
- A10: See Sanitary Sewer Service Notes on Sheet M-01 for information on Trench Undercut pay item.

A copy of the amended pages of the Contract Documents noted in this Addendum No. 3 have been posted online at <http://www.hrcengr.com/bid-info/> and should be utilized during the preparation of the bids and incorporated into the Bid Documents.

If you have any questions or require any additional information, please contact the undersigned.

Very truly yours,

HUBBELL, ROTH & CLARK, INC.



Prasad Gullapalli, P.E.

pc: All Prospective Bidders
Delhi Charter Township; S. Diorka
HRC; T. Sneathen, N. Womack, S. Carver, File

Received and Acknowledged by:

Company Name: _____

Name: _____

Written Name: _____

Address: _____

Telephone: _____ Fax: _____